

Equivalence entre les différentes normes internationales de classification des salles propres

Nbre de part $\geq 0,5\mu\text{m}/\text{m}^3$ (environ)	US Fed. Std 209 E 1992	US Fed. Std 209 E AN-GLAIS 1991	EN ISO 14644-1 1996	"France AFNOR NFX44101 1981"	BPF / GMP Europe Indust. Pharm. 1989	Nbre de part $\geq 0,1\text{m}/\text{m}^3$ (environ)
			ISO 1			10
1						35
4			ISO 2			100
10	M1					350
35	M 1.5	1	ISO 3			1000
100	M2					3500
353	M 2.5	10	ISO 4			10000
1 000	M3					35000
3530	M 3.5	100	ISO 5	4000	A et B	100000
10000	M4					350 000
35300	M 4.5	1 000	ISO 6			1 000 000
100000	M5					
353 000	M 5.5	10000	ISO 7	400000	C	
1 000 000	M6					
3 530 000	M 6.5	100000	ISO 8	4000000	D	
10 000 000	M 7					
35 530 000			ISO 9			